



Regional Water Testing Laboratory, (Uttar Pradesh Jal Nigam, Gorakhpur)

Address: EWS 388,389,390 Rapti Nagar Phase-I, Medical Road, Gorakhpur(U.P)-273003

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	93	/Camp / Lab-I	Date:	18/07/2025	Page No	1/1
Customer Details						
Office Name and Address	Evergreen World School, Jungle Tinkonia No.02 Tola-Sakhwania Pipraich Gorakhpur					
Ref Letter No & Date	14/07/2025					
Basic details of sample						
District	Gorakhpur	Block	--			
Gram Panchayat	--	Village	--			
Habitation	--	Location	Evergreen World School, Jungle Tinkonia No.02 Tola-Sakhwania Pipraich Gorakhpur			
Water Source	R.O	Sample Code	(C/25/07/04)			
Quantity of Sample	500ml	Date of S.C.	14/07/2025			
Receiving Date	14/07/2025	S. Collector	RPN Singh			
Sample Depositor	RPN Singh	Analysis Completion Date	17/07/2025			
Analysis Start Date	15/07/2025					

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH (25°C ± 2°C)	7.49		6.5-8.5	No relaxation	IS 3025 (Part 11):2017
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025 (PART 26) : 1986
3	Total Coliform	0	CFU	0	CFU	APIA 23 rd Edition :2017
4	E.Coli	0	CFU	0	CFU	APIA 23 rd Edition :2017

Result : Satisfactory

Remark: Potable

Note 1. This Certificate refers only to the particular sample(s) submitted for testing.

- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of tests reports unless.

Analysed By

Authorized Signatory

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact - +91 8604561988

-----End of the Report-----

Ranvir
Director
Evergreen World School
Jungle Tinkonia No.-2
Sakhwania, Gorakhpur